

Deskripsi Artikel

- Judul Jurnal : Jurnal Polimesin
- Volume Jurnal : Volume 23, Nomor 1, 2025
- Akreditasi : SINTA 2
- Judul Artikel : Enhancing Seawater Desalination Performance Using a Vortex Generator in a Modified Window Air Conditioner
- Penulis : Nurkholid, **Dan Mugisidi**, Widodo, Oktarina Heriyani, Ibnu Sulistiono.
- Status Penulis : Penulis ke 2, Koresponding.



Jurnal Polimesin

Disseminating information on the
research of mechanical engineering.

Indexed: ICI, Accredited: Sinta 2

<http://e-jurnal.pnl.ac.id/polimesin>

Volume: 16, No. 2, August 2022

ISSN-p: 1693-5462, ISSN-e: 2549-1199

Department of mechanical engineering

Lhokseumawe State Polytechnic

Keywords: Aceh Coffee Brewing Process, CAD/ CAM,
Thermal Energy, DOE, Level Control floating valve, Sink
Faucet Solar Collector Design of Work Tool, Air Blower,
SMAW, Friction Stir Welding Processing Step, microstructure



JURNAL POLIMESIN
POLITEKNIK NEGERI LHOKSEUMAWA
P-ISSN : 16935462 <> E-ISSN : 25491199 Subject Area : Science, Engineering

**0.748858**
Impact

**1103**
Google Citations

**Sinta 2**
Current Accreditation

🔍 Google Scholar

🦅 Garuda

🌐 Website

🔗 Editor URL

History Accreditation

2017	2018	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029
🟡	🟡	🟡	🟡	🟢	🟢	🟢	🟢	🟢	🟢	🟢	🟢	🟢

Garuda

Google Scholar

Taguchi-based optimization of sheeting machine parameters for improved production speed

Politeknik Negeri Lhokseumawe Jurnal Polimesin Vol 23, No 1 (2025): February 83-88

📅 2025 📄 DOI: 10.30811/jpl.v23i1.5612 🏆 Accred : Sinta 2

Optimizing the making of written batik on mori cloth automatically using programmed canting motion with temperature and feed-rate analysis

Politeknik Negeri Lhokseumawe Jurnal Polimesin Vol 23, No 1 (2025): February 128-133

📅 2025 📄 DOI: 10.30811/jpl.v23i1.5635 🏆 Accred : Sinta 2

Mechanical and microstructural effects of varying welding currents in GTAW of 7075-T62 aluminum



Editorial Team

<https://e-jurnal.pnl.ac.id/index.php/polimesin/about/editorialTeam>



Jurnal Polimesin

Disseminating information on the research of mechanical engineering
Index: ICI, SINTA 2, Google Scholar ISSN Online: 2549-1199, ISSN Print: 1693-5462
Department of Mechanical Engineering, Uhokeumawe State Polytechnic, Uhokeumawe 12181, Indonesia

HOME ABOUT LOGIN SEARCH CURRENT ARCHIVES ANNOUNCEMENTS FOCUS & SCOPE EDITORS REVIEWERS REGISTER GUIDELINE

Home > About the Journal > Editorial Team

Editorial Team

Editor in Chief
A. Jannifar, PhD, Politeknik Negeri Lhokseumawe, Scopus Author ID: 55123253500, Indonesia

Managing Editor
Azwinur Azwinur, Politeknik Negeri Lhokseumawe, Scopus Author ID: 57209408481, Indonesia

Associate Editors
Rahadian Nopriantoko, Universitas Krisnadwipayana, Indonesia
Mr. Lasista Ari Nendra Wibawa, Badan Riset dan Inovasi Nasional (BRIN) Scopus ID: 57217102709 Sinta ID: 6670715, Indonesia
Dr. Omer A. Alawi, Universiti Teknologi Malaysia, Scopus ID: 56108584300, Malaysia
Prof. Dr. Iskandar Hasanuddin, Mechanical and Industrial Engineering Department, Universitas Syiah Kuala, Darussalam, Banda Aceh, Indonesia, Author Scopus ID: 57203218451, Indonesia
Dr. Irwin Syahri Cebro, Politeknik Negeri Lhokseumawe, Author Scopus ID: 57203138585, Indonesia
Dr. Samsul Bahri, Politeknik Negeri Lhokseumawe, Scopus Author ID: 57203144032, Indonesia
Syukuran Syukuran, Politeknik Negeri Lhokseumawe, ID Scopus: 5595422000, AP4-RWS, Indonesia
Muhammad Aidi, Universitas Negeri Makassar, Author Scopus ID: 57346145400, Indonesia
Alex Taufiqurrahman Zain, Politeknik Negeri Jember, Author Scopus ID: 57222958035, Indonesia
Amir Zaki Mubarak, Syiah Kuala University, Scopus Author ID: 57190937549
Riki Effendi, University of Muhammadiyah Jakarta, Scopus Author ID: 57223930959, Indonesia
Dr. Faisal Muhammad Nur, Universitas Malikussaleh, Scopus Author ID: 57201065285, Indonesia
Zulkifli Zulkifli, Politeknik Negeri Balikpapan, Indonesia

Advisory International Editorial Boards
Prof. Dr-ing, Yupiter HP Manurung, Universiti Teknologi MARA, Scopus Author ID: 36768369500, Malaysia
Prof. Dr. Ir. Wahyu Kuntjoro, Universiti Teknologi Mara, Scopus Author ID: 26429710100, Malaysia
Assoc. Prof. Dr. Nor Azwadi Che Sidik, Universiti Teknologi Malaysia, Scopus Author ID: 57204852231, Malaysia
Prof. Dr. Ghulamullah Khan, Balochistan University of Information Technology, Engineering and Management Sciences (BUITEMS) Quetta Balochistan, Scopus ID: 57696647500, Pakistan
Prof. Dr. Huzaini Huzaini, Scopus Author ID: 18039973700, Syiah Kuala University, Indonesia
Prof. Dr. Ahmad Syuhada, Scopus Author ID: 650723785, Syiah Kuala University, Indonesia
Dr. Abdul Rahman Mohamed Mallaah, R&D Engineer affan Electric Systems, affan Group Riyadh, Scopus Author ID: 57203285563, Saudi Arabia
Assoc. Prof. Dr. Thanh-Long Le, Ho Chi Minh City University of Technology (HCMUT), VNU-HCM, Scopus Author ID: 56482723600, Viet Nam

Copieditors

Publication Ethics
Open Access Policy
Online Submission
Peer Review Process
Author Fees
Abstracting & Indexing

COLLABORATED WITH PDRI

MoU Jurnal Polimesin-PDRI

Supported by:

ijournal
JURNAL INDONESIA

ARTICLE TEMPLATE

Journal Template

ISSN

P-ISSN: 1693-5462 | E-ISSN: 2549-1199

Daftar Isi

<https://e-jurnal.pnl.ac.id/polimesin/index>



Jurnal Polimesin

Disseminating information on the research of mechanical engineering
Index: ICI, SINTA 2, Google Scholar ISSN Online: 2549-1199, ISSN Print: 1693-5462
Department of Mechanical Engineering, Uhokeumawe State Polytechnic, Uhokeumawe 12181, Indonesia

HOME ABOUT LOGIN SEARCH CURRENT ARCHIVES ANNOUNCEMENTS FOCUS & SCOPE EDITORS REVIEWERS REGISTER GUIDELINE

Home > Vol 23, No 2 (2025)

Jurnal Polimesin

The Jurnal Polimesin is a peer-reviewed journal that publishes original, high-quality research papers on all branches of mechanical engineering. The editorial team's goal is to publish highly applied research and breakthroughs that can be disseminated while also recognizing the potential of mechanical engineering. This journal is published every two months: in February, April, June, August, October, and December.

Several Department of Mechanical Engineering members created and led the editorial team for this publication, which Uhokeumawe State Polytechnic produced in partnership with the Indonesian Lecturer Brotherhood.

This journal has been accredited by the National Journal Accreditation Institute (ANJINA), which is controlled by the Republic's Ministry of Research, Technology, and Higher Education

PREFIX DOI:
<http://dx.doi.org/10.30811/jp1>

CONTACT US:
Registration, submission, and LOA
WhatsApp: +6289529125780
e-mail: polimesin@gmail.com

General Inquiring
e-mail: polimesin@gmail.com

Announcements

Accreditation: SINTA-2

Recently, Polimesin is accredited as the SINTA-2. From now, it is on the board of a prestigious journals in the Indonesian government indexing body, called SINTA (Science and Technology Index). Briefly, SINTA is a program under the education and culture ministry to encourage scientific publication in Indonesia, especially in a journal.

Posted: 2022-01-01

More...

Publication Ethics
Open Access Policy
Online Submission
Peer Review Process
Author Fees
Abstracting & Indexing

COLLABORATED WITH PDRI

MoU Jurnal Polimesin-PDRI

Supported by:

ijournal
JURNAL INDONESIA

ARTICLE TEMPLATE

Journal Template

ISSN

P-ISSN: 1693-5462 | E-ISSN: 2549-1199

Enhancing Seawater desalination performance using a vortex generator in a modified window air conditioner

Nurkholid¹, Dan Mugisidi^{1*}, Widodo², Oktarina Heriyani¹, Ibnu Sulistiono¹

¹Department of Mechanical Engineering, University of Muhammadiyah Prof. Dr. Hamka, Jakarta 13830, Indonesia

²Department of Mechanical Engineering, Polytechnic of Enjinering Indorama, Purwakarta 41152, Indonesia

*Corresponding author: dan.mugisidi@uhamka.ac.id

Abstract

The growing demand for air conditioning systems has driven research into alternative applications, such as seawater desalination. This study evaluates the performance of a modified Window Air Conditioner (WAC) integrated with a vortex generator for desalination. Experiments were conducted using R410A refrigerant under four conditions: Closed Container (CC), Without Vortex (WV), Connected Vortex (CV), and Separated Vortex (SV). Seawater was heated via the condenser to 55-60°C, controlled by a thermostat, and data was collected every five minutes over eight hours. The thermodynamic properties of R410A were analysed using Refprop™ software to determine the Refrigeration Effect (RE), Compression Work (CW), and Coefficient of Performance (COP). Results indicate that the SV configuration achieved the highest evaporation rate (5.01 kg) but led to a lower COP (3.91) due to increased condenser temperature and compressor workload. Conversely, CC yielded the highest COP (5.08) by stabilizing the evaporator air temperature and reducing compressor effort. These findings suggest that vortex generators enhance evaporation rates but reduce system efficiency. Further research is needed to optimize vortex generator configurations to improve desalination efficiency while minimizing COP reduction.

Keywords:

Window air conditioner, vortex generator, desalination, Refprop™, COP

1 Introduction

Along with the improvement of the quality of life and the need for comfort, the use of air conditioning systems is increasing in daily life [1], [2]. Air conditioning systems also help remove moisture and airborne particles from the room [3]. Therefore, the use of air conditioners is no longer just part of a lifestyle but rather aims to provide comfort when moving or doing activities indoors [4]. One of the most common types is the Window Air Conditioner (WAC), which uses a vapor compression cycle to take heat from the air inside and expel it outside through condensation [5]. This condensation water is usually disposed of as waste but can be used to make clean water under certain conditions [6]. The high demand for clean water around the world, as well as environmental issues such as drought and limited availability of clean water resources, are major challenges that need to be addressed [7], [8], [9]. The use of a modified WAC as a desalination device is an option to consider. This modification allows the WAC to function as both an air conditioning unit and a system to separate salt from saltwater.

Evaluating the performance of the WAC as a desalination device is essential to ensure the effectiveness of this system in removing salt from seawater.

Desalination systems, such as reverse osmosis (RO), are currently available [10]. However, such technologies consume much energy [11], especially on a large scale, making it inefficient for households or places with limited energy resources. On the other hand, WAC is a device that is widely used in many homes [12] and operates according to the principles that allow it to be used in desalination processes. The main problem is how to modify the WAC without compromising its cooling efficiency and ensuring optimal system performance during its switch to desalination function.

Research on the use of air conditioning for desalination processes is still in its infancy. Some of the research that has been conducted includes the integration of a split air conditioning system with a Humidification-Dehumidification (HDH) desalination unit utilizing solar energy, the utilization of solar heating to improve the performance of a hybrid desiccant air conditioning system coupled with an HDH desalination unit, numerical analysis of a hybrid air conditioning system supported by solar energy and integrated with an HDH desalination system, and modified window air conditioner to produce potable water through humidification-dehumidification desalination process [13], [14], [15], [16]. These experiments show that combining an air conditioning system with a desalination unit can produce clean water. Nevertheless, these studies have not investigated the impact of vortex generators on desalination effectiveness, particularly in enhancing the evaporation rate. Multiple studies have investigated the application of vortex generators in desalination to enhance the evaporation rate [17], [18], given that vortex generators influence the convection heat transfer coefficient [19]. Previous research has not examined the performance of WAC modified with a vortex generator as a desalination tool against seawater evaporation. Desalination itself is the process of separating salt and minerals from seawater to produce freshwater [20]. Cooling system performance can be determined by assessing the Refrigeration Effect (RE), Compression Work (CW), and Coefficient of Performance (COP) [21].

Therefore, this study aims to determine the performance of the modified WAC as a desalination device against seawater evaporation. This research has analysed the impact of various tested variables on the evaporation of seawater at a given temperature. The desalination mechanism focuses on the evaporation process, where seawater is evaporated using the modified WAC. The performance assessment of this system uses the parameters RE, CW, and COP, which are the main indicators in assessing the ability of the device as a desalination system. It is hoped that this research can provide a deep insight into the potential of WAC modification to produce a more effective and efficient desalination system.

2 Method

This study used a WAC to compare its performance as a desalination device. The experimental setup used in this study is presented in Fig. 1. The working fluid of the air conditioning system is R410A refrigerant [22] with the specifications shown in Table 1. This research was conducted at the Mechanical Engineering Laboratory, Faculty of Industrial Technology and Informatics, Universitas Muhammadiyah Prof. Dr. Hamka. In addition, the measurement tools used are listed in Table 2. Tests on the utilization of WAC as a desalination tool were carried out with variables of Closed Container (CC), Without Vortex (WV), Connected Vortex (CV), and Separate Vortex (SV) (Fig. 2).

Refprop™ software version 10.0.0.9b is used to determine the properties of the refrigerant at enthalpy at each point based on the cooling system performance data by analyzing the saturation pressure, temperature, enthalpy, entropy, and density of the refrigerant [24], [25]. System performance is analyzed using

pressure and temperature obtained through calculations on R410A refrigerant using RefpropTM software [26]. The effectiveness of an air conditioner is evaluated by determining the refrigeration effect, which is the difference in refrigerant enthalpy between the evaporator's inlet and outlet, and the compression work, which is the enthalpy difference between the compressor's outlet and inlet. The values of RE, CW, and Coefficient of COP are determined based on the obtained enthalpy results [27].




Fig. 1. Experimental setup

Table 1. Refrigeration unit specifications


Dimension	Specification
Model WAC	Uchida MP – W9M
Voltage	1 Fase 220V – 50 Hz
PK Power	1 PK
Cooling Capacity	8600 BTU/h
Electrical power	840 W
Current	4.0 A
EER	10.01 BTU/hW
Refrigerant R410A	360 g
Size	500×345×465 mm

Table 2. Measurement tools


Tools	Function	Specification
Thermostat XH-W3001	Water temperature	-50°C -110°C, ±0.1°C.
Digital thermometer	Temperature	-50°C -110°C, ±0.1°C.
Manifold Gauge	Pressure	0 – 500 psi, 5 psi
Digital scale 30 kg	Water Mass	0 – 30 kg, 0.005 kg

In this experiment, the seawater in the evaporation container is transferred to the control container via a pump. This step aims to deliver the water to the main container, where it will be heated using a condenser until the temperature reaches about 55-60°C, which is regulated by a thermostat. As the water evaporates, the resulting vapor is directed upwards through the steam funnel before finally entering the evaporator. The main container has an overflow mechanism that delivers water to the evaporation container to maintain the temperature in the range of 55-60°C. In addition, the control container is also equipped with an overflow system for the evaporation container to ensure the water level remains stable. This system allows the control container's water level to remain constant while the evaporation container's water level drops due to the evaporation process [23]. The evaporation rate was determined by the mass of water in the evaporation container, which was measured with a digital scale to confirm the amount of water lost owing to evaporation. In Fig. 1 data was collected at P₁, T₁, P₂, T₂, P₃, T₃, P₄, T₄, T₅, T₆, T₇. Where P₁, T₁ is the compressor inlet pressure, temperature, P₂, T₂ is the compressor outlet pressure, temperature, P₃, T₃ is the expansion inlet pressure, temperature, P₄, T₄ is the expansion outlet pressure, temperature, T₅ is the condenser temperature, T₆ is the evaporator temperature, T₇ is the evaporator outlet air temperature, and the


variable location is used for a closed container by placing a plate on top of the container, a container without vortex, vortex connected, and vortex separated. Figs 3-4 shows the vortex used in this study.




(a) Closed container (CC) location



(b) Without vortex (WV) location



(c) Connected vortex (CV) location



(d) Separated vortex (SV) location

Fig. 2. Variable location




Fig. 3. Connected vortex (CV)




Fig. 4. Separated vortex (SV)

Refrprop™ software version 10.0.0.9b is used to determine the properties of the refrigerant at enthalpy at each point based on the cooling system performance data by analyzing the saturation pressure, temperature, enthalpy, entropy, and density of the refrigerant [24], [25]. System performance is analysed using pressure and temperature obtained through calculations on R410A refrigerant using Refprop™ software [26]. The effectiveness of an air conditioner is evaluated by determining the refrigeration effect, which is the difference in refrigerant enthalpy between the evaporator's inlet and outlet, and the compression work, which is the enthalpy difference between the compressor's outlet and inlet. The values of RE, CW, and COP are determined based on the obtained enthalpy results [27]. The RE, CW, COP are determined using Eqs(1-3) [28]. Where: h_1 is enthalpy at the compressor inlet, h_2 is Enthalpy at the compressor outlet, and h_4 is enthalpy at the Evaporator inlet.

$$RE = h_1 - h_4 \quad (1)$$

$$CW = h_2 - h_1 \quad (2)$$

$$COP = \frac{RE}{CW} = \frac{h_1 - h_4}{h_2 - h_1} \quad (3)$$

3 Results and Discussion

This study examines the performance of WAC for utilization as a desalination tool with four variables: CC, WV, CV, and SV. Fig. 5 shows the data collection process. At points 1 to 4, data of P_1 , T_1 , P_2 , T_2 , P_3 , T_3 , P_4 , and T_4 are collected sequentially. The digital scale at point 5 is used to measure the mass of water in the evaporation container to determine the decrease in mass due to evaporation. The seawater in the main container was heated by a condenser controlled by a thermostat to maintain a temperature between 55-60°C. Data was collected every 5 minutes for 8 hours. The system performance is greatly affected by the evaporation rate, which impacts the COP value of the WAC. In addition, this process demonstrates how the integration of vortex generators can improve desalination efficiency.




Fig. 5. WAC as a desalination devices

Fig. 6 shows the pressure-enthalpy (P-h) diagram for R410A refrigerant at various variables, namely CC, WV, CV, and SV. The enthalpy values are obtained from the calculation results using Refprop™ software, with input data in the form of pressure and temperature at each point: P_1 , T_1 , P_2 , T_2 , P_3 , T_3 , P_4 , and T_4 . The average evaporator exit air temperature for each variable is 17.8°C, 18.6°C, 18.7°C, and 18.9°C, respectively. Meanwhile, the condenser exit air temperatures were 55.7°C, 56.3°C, 56.9°C, and 57.1°C, respectively. Based on the enthalpy values obtained, the performance of the WAC system can be calculated, including the RE, CW, and COP values.




Fig. 6. P-h diagram for R410A with a closed container, without vortex, connected vortex, and separated vortex

In a refrigeration system, efficiency is crucial to consider. One concept that plays a role in measuring the efficiency of a refrigeration system is the RE, which is the amount of heat absorbed by the refrigerant in the evaporator for each unit mass of cooling, which occurs in the process from 4 to 1 [29], [30]. By calculating using Eq. 1, the RE of R410A for various CC, WV, CV, and SV variables in the desalination process is shown in Fig. 7. The results show a decrease in RE; a lower refrigeration effect can lower COP [31]. The latent heat of vaporization in the Air Conditioning (AC) system comes from the evaporation of refrigerant [32]. The closed container of R410A has the highest RE value. The high RE value is due to the latent heat of vaporization [33] and high enthalpy compared to the other variable, R410A. As a result, the desalination process using closed-container R410A yields better cooling capacity than the other variable, R410A.




Fig. 7. Refrigeration effect and compression work with closed container, without vortex, connected vortex, and separated vortex.

Meanwhile, the CW of R410A for various variables, the CW value in the figure is calculated using Eq.2. Unlike RE, CW has a constant increase. This is due to the increase in compressor pressure, the refrigerant temperature [34], and enthalpy. An increase in refrigerant pressure can increase compressor work, thus decreasing the COP value [35]. CW of the closed container R410A is lower than that of the other variable R410A. This indicates that the R410A refrigerant in the sealed container has a lower temperature, so the compressor workload is lighter [36].

The COP is calculated using Eq. 3, and Fig. 8 shows that the COP value decreases as the evaporation increases. The use of a vortex increases the evaporation rate and efficiency in the desalination unit, resulting in faster evaporation [37], [38]. CV and SV have different geometry so it can affect the characteristics of airflow. CV has fewer and connected, while SV with more separated numbers produces better evaporation and increased effectiveness [39].




Fig. 8. Evaporation and COP with closed container, without vortex, connected vortex, and separated vortex.

On the other hand, an increase in refrigerant in the refrigeration machine can lead to an increase in temperature in the condenser, which requires greater compression effort [40]. The condenser located inside the main container helps to heat the water and increase evaporation as the temperature rises. The increased evaporation temperature from the condenser is then transferred to the evaporator through a steam funnel designed to direct the incoming air to the evaporator. The CC is secured with plates to prevent evaporation in the condenser from affecting the temperature of the air entering the evaporator. This causes a high refrigeration effect and reduces compression work, resulting in an optimal COP.

4 Conclusion

This study demonstrates that incorporating a vortex generator into a modified WAC significantly impacts seawater evaporation

rates in desalination. The SV configuration produced the highest evaporation rate (5.01 kg) but reduced system efficiency by increasing compressor workload, leading to a lower COP (3.91). Conversely, the CC condition achieved the highest COP (5.08) by minimizing heat loss and stabilizing air temperature entering the evaporator. These findings highlight the trade-off between evaporation enhancement and system efficiency.

Future research should explore alternative vortex configurations, large scale testing, and environmental variations to optimize WAC-based desalination systems.

Acknowledgment

The author would like to express sincere gratitude for the in-kind support provided by the Renewable Energy Research Group at FTII UHAMKA.

References

- [1] P. Martínez, J. Ruiz, C. G. Cutillas, P. J. Martínez, A. S. Kaiser, and M. Lucas, "Experimental study on energy performance of a split air-conditioner by using variable thickness evaporative cooling pads coupled to the condenser," *Appl. Therm. Eng.*, vol. 105, pp. 1041–1050, 2016, doi: 10.1016/j.applthermaleng.2016.01.067.
- [2] M. H. Alhamdo, M. A. Theeb, and J. J. Abdulhameed, "Using evaporative cooling methods for improving performance of an Air-cooled Condenser," *Univers. J. Mech. Eng.*, vol. 3, no. 3, pp. 94–106, 2015, doi: 10.13189/ujme.2015.030304.
- [3] K. Harby, D. R. Gebaly, N. S. Koura, and M. S. Hassan, "Performance improvement of vapor compression cooling systems using evaporative condenser: An overview," *Renew. Sustain. Energy Rev.*, vol. 58, pp. 347–360, 2016, doi: 10.1016/j.rser.2015.12.313.
- [4] N. D. Purnama, T. P. Pramudiantoro, and A. Badarufin, "Kaji eksperimental perbandingan performansi ac split sebelum dan sesudah pemanfaatan panas buang kondenser untuk alat penetas telur," *Pros. Ind. Res. Work. Natl. Semin.*, vol. 15, no. 1, pp. 64–70, 2024, doi: 10.35313/irwns.v15i1.6242.
- [5] N. I. Ibrahim, A. A. Al-Farayedhi, and P. Gandhidasan, "Experimental investigation of a vapor compression system with condenser air pre-cooling by condensate," *Appl. Therm. Eng.*, vol. 110, pp. 1255–1263, 2017, doi: 10.1016/j.applthermaleng.2016.09.042.
- [6] M. W. Akram, R. Mursalin, M. M. Hassan, M. R. Islam, and S. K. Choudhury, "recycling of condensed water from an air conditioning unit," in *International Conference on Computer, Communication, Chemical, Material and Electronic Engineering, IC4ME2, IEEE*, 2018, pp. 1–5. doi: 10.1109/IC4ME2.2018.8465612.
- [7] A. Gross and E. Park, "Water and wastewater treatment worldwide: The industry and the market for equipment and chemicals," *Bus. Econ.*, vol. 53, no. 2, pp. 37–47, 2018, doi: 10.1057/s11369-018-0069-1.
- [8] D. Mugisidi, A. Fajar, and H. Oktarina, "Peningkatan efisiensi dan efektivitas kondensor pada solar still," *J. Teknosains*, vol. 12, no. 1, pp. 19–31, 2022.
- [9] J. J. Messakh, A. Sabar, I. K. Hadihardaja, and A. A. Chalik, "A study on fulfillment of drinking water need of people in semi-arid areas in Indonesia," *J. Mns. dan Lingkung.*, vol. 22, no. 3, pp. 271–280, 2015.
- [10] A. A. Ragetisvara and H. S. Titah, "Studi kemampuan desalinasi air laut menggunakan sistem sea water reverse osmosis (swro) pada kapal pesiar," *J. Tek. ITS*, vol. 10, no. 2, pp. 68–75, 2021, doi: 10.12962/j23373539.v10i2.63933.
- [11] L. A. Yoshi and I. N. Widiasta, "Prosiding seminar nasional teknik kimia 'kejuangan' sistem desalinasi membran reverse osmosis (RO) untuk penyediaan air bersih," in *Prosiding Seminar Nasional Teknik Kimia "Kejuangan"*, 2016, pp. 1–7.

- [12] B. Shen and B. Fricke, "Development of high efficiency window air conditioner using propane under limited charge," *Appl. Therm. Eng.*, vol. 166, p. 114662, 2020, doi: 10.1016/j.applthermaleng.2019.114662.
- [13] A. E. Kabeel, M. Abdelgaied, and Z. M. Omara, "Experimentally evaluation of split air conditioner integrated with humidification-dehumidification desalination unit for better thermal comfort, produce freshwater, and energy saving," *J. Therm. Anal. Calorim.*, vol. 147, no. 6, pp. 4197–4207, 2022, doi: 10.1007/s10973-021-10810-6.
- [14] M. Abdelgaied, A. E. Kabeel, and Y. Zakaria, "Performance improvement of desiccant air conditioner coupled with humidification-dehumidification desalination unit using solar reheating of regeneration air," *Energy Convers. Manag.*, vol. 198, p. 111808, 2019, doi: 10.1016/j.enconman.2019.111808.
- [15] A. E. Kabeel, M. Abdelgaied, and Y. Zakaria, "Performance evaluation of a solar energy assisted hybrid desiccant air conditioner integrated with HDH desalination system," *Energy Convers. Manag.*, vol. 150, pp. 382–391, 2017, doi: 10.1016/j.enconman.2017.08.032.
- [16] P. Dalai, P. Nanda, C. Mund, D. Mishra, and A. Gupta, "An experimental study on water harvesting from a modified window air-conditioner," *Energy Procedia*, vol. 109, pp. 253–260, 2017, doi: 10.1016/j.egypro.2017.03.058.
- [17] D. Mugisidi and O. Heriyani, "Improving the performance of a forced-flow desalination unit using a vortex generator," *CFD Lett.*, vol. 16, no. 10, pp. 81–93, 2024, doi: 10.37934/cfdl.16.10.8193.
- [18] A. N. Shmroukh, A. A. Serageldin, A. Abdal-hay, A. Elreedy, and A. Radwan, "Application of new series connection scheme of vortex tubes in seawater desalination unit using new vortex generators," *SN Appl. Sci.*, vol. 3, pp. 1–13, 2021, doi: 10.1007/s42452-021-04205-3.
- [19] O. Heriyani, M. Djaeni, Syaiful, and A. K. Putri, "Perforated concave rectangular winglet pair vortex generators enhance the heat transfer of air flowing through heated tubes inside a channel," *Results Eng.*, vol. 16, pp. 1–15, 2022, doi: 10.1016/j.rineng.2022.100705.
- [20] J. Williams, "Desalination in the 21st Century: A Critical Review of Trends and Debates," *Water Altern.*, vol. 15, no. 2, pp. 193–217, 2022.
- [21] Widodo, F. Rachmanu, and A. I. Tauvana, "analysis of savings on electricity consumption in room air conditioning by using r1270 (propylene) refrigerant instead of R32 capacity of 13,000 Btuh," *J. Phys. Conf. Ser.*, vol. 1477, no. 5, pp. 1–6, 2020, doi: 10.1088/1742-6596/1477/5/052035.
- [22] I. G. A. Negara et al., "Real-time thermodynamic monitoring of split inverter ACs: a microcontroller-driven investigation of performance," *J. Polimesin*, vol. 22, no. 2, pp. 199–205, 2024.
- [23] R. Wirangga, D. Mugisidi, A. T. Sayuti, and O. Heriyani, "The impact of wind speed on the rate of water evaporation in a desalination chamber," *J. Adv. Res. Fluid Mech. Therm. Sci.*, vol. 106, no. 1, pp. 39–50, 2023, doi: 10.37934/arfmts.106.1.3950.
- [24] E. W. Lemmon, I. H. Bell, M. L. Huber, and M. O. McLinden, "NIST Standard reference database 23: reference fluid thermodynamic and transport properties-REFPROP, version 10.0, National Institute of Standards and Technology."
- [25] M. L. Huber, E. W. Lemmon, I. H. Bell, and M. O. McLinden, "The NIST REFPROP database for highly accurate properties of industrially important fluids," *Ind. Eng. Chem. Res.*, vol. 61, no. 42, pp. 15449–15472, 2022, doi: 10.1021/acs.iecr.2c01427.
- [26] Widodo, B. Fajar, T. Suryo, and Winoto, "Simulation of mixing synthetic with hydrocarbons refrigerant to reduce the value of global warming potential with refprop software," *J. Phys. Conf. Ser.*, vol. 1764, no. 1, pp. 1–6, 2021, doi: 10.1088/1742-6596/1764/1/012158.
- [27] M. E. Pujianto and A. Nugroho, "Performance air conditioner on retrofitted refrigerant hydrocarbon," *J. Polimesin*, vol. 22, no. 1, pp. 15–18, 2024, doi: 10.1063/1.5049962.
- [28] K. Sumeru, M. Arman, I. Wellid, L. M. Simbolon, A. Setyawan, and M. F. bin Sukri, "Investigation of automotive air conditioning using eco-friendly R600a as an alternative refrigerant to R134a," *J. Polimesin*, vol. 22, no. 1, pp. 35–39, 2024, doi: 10.30811/jpl.v22i1.4463.
- [29] R. K. Sahu, Vinay, and A. Das, "Refrigerating effect produced by engine exhaust heat," *Adv. Fluid Therm. Eng.*, pp. 489–498, 2019, doi: 10.1007/978-981-13-6416-7_45.
- [30] I. N. Ardita and I. P. S. Negara, "Pengaruh heat recovery pada sistem refrigerasi pengkondisian udara terhadap performansi sistem," *J. Log.*, vol. 16, no. 3, pp. 199–203, 2016.
- [31] W. Widodo, B. F. T. Kiono, S. H. Winoto, and M. S. K. T. S. Utomo, "A simulation of R32 refrigerant mixing with R1270 to reduce GWP R410A on wall mounted air conditioning," *IOP Publ.*, vol. 1098, no. 6, pp. 1–7, 2021, doi: 10.1088/1757-899x/1098/6/062111.
- [32] G. Fekadu and S. Subudhi, "Renewable energy for liquid desiccants air conditioning system: A review," *Renew. Sustain. Energy Rev.*, vol. 93, pp. 364–379, 2018, doi: 10.1016/j.rser.2018.05.016.
- [33] Y. Sun, J. Wang, and Y. Hu, "Effect of refrigerant/oil solubility on thermodynamic performance of the evaporator working with R600a and DME," *J. Chem. Thermodyn.*, vol. 154, pp. 1–8, 2021, doi: 10.1016/j.jct.2020.106331.
- [34] S. M. Moosania and X. Zheng, "Performance improvement of a high pressure ratio centrifugal compressor by integrated cooling," *Proc. Inst. Mech. Eng. Part G J. Aerosp. Eng.*, vol. 230, no. 12, pp. 2233–2240, 2015, doi: 10.1177/0954410015622964.
- [35] Widodo, B. F. T. Kiono, S. H. Winoto, and T. S. Utomo, "Performance analysis of using hydrocarbon mixed refrigerant r32-r290 as an alternative to R410A in reducing the GWP value of household split air conditioners," *J. Adv. Res. Fluid Mech. Therm. Sci.*, vol. 107, no. 2, pp. 103–116, 2023, doi: 10.37934/arfmts.107.2.103116.
- [36] A. Setyawan, "Enhancing air conditioner efficiency through evaporative cooling of the compressor: field test results," *Int. J. Heat Technol.*, vol. 42, no. 3, pp. 1073–1080, 2024, doi: 10.18280/ijht.420334.
- [37] O. Heriyani, M. Djaeni, and Syaiful, "Thermal-hydraulic performance analysis by means of rectangular winglet vortex generators in a channel: An Experimental Study," *Eur. J. Eng. Technol. Res.*, vol. 6, no. 3, pp. 150–153, 2021, doi: 10.24018/ejers.2021.6.3.2424.
- [38] M. A. Saad, A. E. Tourab, M. H. Salem, and A. Ismail, "Multifaceted analytical and computational fluid dynamics investigations of vortex tube technology for the optimization of seawater desalination efficiency," *Results Eng.*, vol. 25, pp. 1–12, 2025, doi: 10.1016/j.rineng.2025.104004.
- [39] D. Mugisidi, O. Heriyani, P. H. Gunawan, and D. Apriani, "Performance improvement of a forced draught cooling tower using a vortex generator," *CFD Lett.*, vol. 13, no. 1, pp. 45–57, 2021, doi: 10.37934/cfdl.13.1.4557.
- [40] A. I. Rifa'i and Novarini, "pengaruh tekanan refrigeran r-134a terhadap nilai coefficient of performance (COP)," *J. Inov.*, vol. 1, no. 1, pp. 1–5, 2018, doi: 10.37338/ji.v3i2.136.

Layanan Perpustakaan UHAMKA

Enhancing Seawater desalination performance using a vortex generator in a modified window air conditioner

 LK BU OKTA

 Fakultas Teknologi Industri dan Informatika

 Universitas Muhammadiyah Prof. Dr. Hamka

Document Details

Submission ID

trn:oid::1:3243200613

Submission Date

May 8, 2025, 10:00 AM GMT+7

Download Date

May 9, 2025, 8:53 AM GMT+7

File Name

Enhancing_seawater_desalination_performance_using_a_vortex_generator_in_a_modified_windo....pdf

File Size

1.1 MB

5 Pages

4,258 Words

22,988 Characters

14% Overall Similarity

The combined total of all matches, including overlapping sources, for each database.

Filtered from the Report

- Bibliography

Exclusions

- 5 Excluded Matches

Match Groups

-  **40 Not Cited or Quoted 14%**
Matches with neither in-text citation nor quotation marks
-  **0 Missing Quotations 0%**
Matches that are still very similar to source material
-  **0 Missing Citation 0%**
Matches that have quotation marks, but no in-text citation
-  **0 Cited and Quoted 0%**
Matches with in-text citation present, but no quotation marks

Top Sources

- 13%  Internet sources
- 4%  Publications
- 1%  Submitted works (Student Papers)

Integrity Flags

0 Integrity Flags for Review

No suspicious text manipulations found.

Our system's algorithms look deeply at a document for any inconsistencies that would set it apart from a normal submission. If we notice something strange, we flag it for you to review.

A Flag is not necessarily an indicator of a problem. However, we'd recommend you focus your attention there for further review.

Match Groups

- 40 Not Cited or Quoted 14%**
Matches with neither in-text citation nor quotation marks
- 0 Missing Quotations 0%**
Matches that are still very similar to source material
- 0 Missing Citation 0%**
Matches that have quotation marks, but no in-text citation
- 0 Cited and Quoted 0%**
Matches with in-text citation present, but no quotation marks

Top Sources

- 13% Internet sources
- 4% Publications
- 1% Submitted works (Student Papers)

Top Sources

The sources with the highest number of matches within the submission. Overlapping sources will not be displayed.

1	Internet	repository.uhamka.ac.id	3%
2	Internet	e-jurnal.pnl.ac.id	3%
3	Internet	www.researchgate.net	1%
4	Internet	www.coursehero.com	<1%
5	Student papers	University of Salford	<1%
6	Internet	iieta.org	<1%
7	Student papers	CSU, Fullerton	<1%
8	Publication	Nan Wang, Dongxuan Wang, Jungang Dong, Haitao Wang, Renliang Wang, Limin ...	<1%
9	Publication	W Widodo, B F T Kiono, S H Winoto, M S K T S Utomo. "A simulation of R32 refriger...	<1%
10	Publication	Bipul Krishna Saha, Basab Chakraborty, Joydip Mondal, Apostolos Pesyridis, El Mo...	<1%

11	Publication	D.C. Gao, Y.J. Sun, Z. Ma, H. Ren. "A review on integration and design of desiccant ...	<1%
12	Publication	I P S Negara, I M Arsawan. "The analysis of cooling system working performance ...	<1%
13	Internet	etj.uotechnology.edu.iq	<1%
14	Internet	www.neliti.com	<1%
15	Internet	c5785bea-f979-4bab-9955-7d36152cef71.filesusr.com	<1%
16	Internet	catalog.lib.kyushu-u.ac.jp	<1%
17	Internet	docs.lib.purdue.edu	<1%
18	Internet	ouci.dntb.gov.ua	<1%
19	Internet	www.jait.us	<1%
20	Internet	www.mdpi.com	<1%

Processing dates: received on 2024-11-23, reviewed on 2025-01-24, accepted on 2025-02-23 and online availability on 2025-02-28

Enhancing Seawater desalination performance using a vortex generator in a modified window air conditioner

Nurkholid¹, Dan Mugisidi^{1*}, Widodo², Oktarina Heriyani¹, Ibnu Sulistiono¹

¹Department of Mechanical Engineering, University of Muhammadiyah Prof. Dr. Hamka, Jakarta 13830, Indonesia

²Department of Mechanical Engineering, Polytechnic of Enjinering Indorama, Purwakarta 41152, Indonesia

*Corresponding author: dan.mugisidi@uhamka.ac.id

Abstract

The growing demand for air conditioning systems has driven research into alternative applications, such as seawater desalination. This study evaluates the performance of a modified Window Air Conditioner (WAC) integrated with a vortex generator for desalination. Experiments were conducted using R410A refrigerant under four conditions: Closed Container (CC), Without Vortex (WV), Connected Vortex (CV), and Separated Vortex (SV). Seawater was heated via the condenser to 55-60°C, controlled by a thermostat, and data was collected every five minutes over eight hours. The thermodynamic properties of R410A were analysed using Refprop™ software to determine the Refrigeration Effect (RE), Compression Work (CW), and Coefficient of Performance (COP). Results indicate that the SV configuration achieved the highest evaporation rate (5.01 kg) but led to a lower COP (3.91) due to increased condenser temperature and compressor workload. Conversely, CC yielded the highest COP (5.08) by stabilizing the evaporator air temperature and reducing compressor effort. These findings suggest that vortex generators enhance evaporation rates but reduce system efficiency. Further research is needed to optimize vortex generator configurations to improve desalination efficiency while minimizing COP reduction.

Keywords:

Window air conditioner, vortex generator, desalination, Refprop™, COP

1 Introduction

Along with the improvement of the quality of life and the need for comfort, the use of air conditioning systems is increasing in daily life [1], [2]. Air conditioning systems also help remove moisture and airborne particles from the room [3]. Therefore, the use of air conditioners is no longer just part of a lifestyle but rather aims to provide comfort when moving or doing activities indoors [4]. One of the most common types is the Window Air Conditioner (WAC), which uses a vapor compression cycle to take heat from the air inside and expel it outside through condensation [5]. This condensation water is usually disposed of as waste but can be used to make clean water under certain conditions [6]. The high demand for clean water around the world, as well as environmental issues such as drought and limited availability of clean water resources, are major challenges that need to be addressed [7], [8], [9]. The use of a modified WAC as a desalination device is an option to consider. This modification allows the WAC to function as both an air conditioning unit and a system to separate salt from saltwater.

Evaluating the performance of the WAC as a desalination device is essential to ensure the effectiveness of this system in removing salt from seawater.

Desalination systems, such as reverse osmosis (RO), are currently available [10]. However, such technologies consume much energy [11], especially on a large scale, making it inefficient for households or places with limited energy resources. On the other hand, WAC is a device that is widely used in many homes [12] and operates according to the principles that allow it to be used in desalination processes. The main problem is how to modify the WAC without compromising its cooling efficiency and ensuring optimal system performance during its switch to desalination function.

Research on the use of air conditioning for desalination processes is still in its infancy. Some of the research that has been conducted includes the integration of a split air conditioning system with a Humidification-Dehumidification (HDH) desalination unit utilizing solar energy, the utilization of solar heating to improve the performance of a hybrid desiccant air conditioning system coupled with an HDH desalination unit, numerical analysis of a hybrid air conditioning system supported by solar energy and integrated with an HDH desalination system, and modified window air conditioner to produce potable water through humidification-dehumidification desalination process [13], [14], [15], [16]. These experiments show that combining an air conditioning system with a desalination unit can produce clean water. Nevertheless, these studies have not investigated the impact of vortex generators on desalination effectiveness, particularly in enhancing the evaporation rate. Multiple studies have investigated the application of vortex generators in desalination to enhance the evaporation rate [17], [18], given that vortex generators influence the convection heat transfer coefficient [19]. Previous research has not examined the performance of WAC modified with a vortex generator as a desalination tool against seawater evaporation. Desalination itself is the process of separating salt and minerals from seawater to produce freshwater [20]. Cooling system performance can be determined by assessing the Refrigeration Effect (RE), Compression Work (CW), and Coefficient of Performance (COP) [21].

Therefore, this study aims to determine the performance of the modified WAC as a desalination device against seawater evaporation. This research has analysed the impact of various tested variables on the evaporation of seawater at a given temperature. The desalination mechanism focuses on the evaporation process, where seawater is evaporated using the modified WAC. The performance assessment of this system uses the parameters RE, CW, and COP, which are the main indicators in assessing the ability of the device as a desalination system. It is hoped that this research can provide a deep insight into the potential of WAC modification to produce a more effective and efficient desalination system.

2 Method

This study used a WAC to compare its performance as a desalination device. The experimental setup used in this study is presented in Fig. 1. The working fluid of the air conditioning system is R410A refrigerant [22] with the specifications shown in Table 1. This research was conducted at the Mechanical Engineering Laboratory, Faculty of Industrial Technology and Informatics, Universitas Muhammadiyah Prof. Dr. Hamka. In addition, the measurement tools used are listed in Table 2. Tests on the utilization of WAC as a desalination tool were carried out with variables of Closed Container (CC), Without Vortex (WV), Connected Vortex (CV), and Separate Vortex (SV) (Fig. 2).

Refprop™ software version 10.0.0.9b is used to determine the properties of the refrigerant at enthalpy at each point based on the cooling system performance data by analyzing the saturation pressure, temperature, enthalpy, entropy, and density of the refrigerant [24], [25]. System performance is analyzed using

pressure and temperature obtained through calculations on R410A refrigerant using Refprop™ software [26]. The effectiveness of an air conditioner is evaluated by determining the refrigeration effect, which is the difference in refrigerant enthalpy between the evaporator's inlet and outlet, and the compression work, which is the enthalpy difference between the compressor's outlet and inlet. The values of RE, CW, and Coefficient of COP are determined based on the obtained enthalpy results [27].




Fig. 1. Experimental setup

Table 1. Refrigeration unit specifications

Dimension	Specification
Model WAC	Uchida MP – W9M
Voltage	1 Fase 220V – 50 Hz
PK Power	1 PK
Cooling Capacity	8600 BTU/h
Electrical power	840 W
Current	4.0 A
EER	10.01 BTU/hW
Refrigerant R410A	360 g
Size	500×345×465 mm


Table 2. Measurement tools

Tools	Function	Specification
Thermostat XH-W3001	Water temperature	-50°C -110°C, ±0.1°C.
Digital thermometer	Temperature	-50°C -110°C, ±0.1°C.
Manifold Gauge	Pressure	0 – 500 psi, 5 psi
Digital scale 30 kg	Water Mass	0 – 30 kg, 0.005 kg


In this experiment, the seawater in the evaporation container is transferred to the control container via a pump. This step aims to deliver the water to the main container, where it will be heated using a condenser until the temperature reaches about 55-60°C, which is regulated by a thermostat. As the water evaporates, the resulting vapor is directed upwards through the steam funnel before finally entering the evaporator.

The main container has an overflow mechanism that delivers water to the evaporation container to maintain the temperature in the range of 55-60°C. In addition, the control container is also equipped with an overflow system for the evaporation container to ensure the water level remains stable. This system allows the control container's water level to remain constant while the evaporation container's water level drops due to the evaporation process [23]. The evaporation rate was determined by the mass of water in the evaporation container, which was measured with a digital scale to confirm the amount of water lost owing to evaporation. In Fig. 1 data was collected at P₁, T₁, P₂, T₂, P₃, T₃, P₄, T₄, T₅, T₆, T₇. Where P₁, T₁ is the compressor inlet pressure, temperature, P₂, T₂ is the compressor outlet pressure, temperature, P₃, T₃ is the expansion inlet pressure, temperature, P₄, T₄ is the expansion outlet pressure, temperature, T₅ is the evaporator temperature, T₆ is the evaporator temperature, T₇ is the evaporator outlet air temperature, and the


variable location is used for a closed container by placing a plate on top of the container, a container without vortex, vortex connected, and vortex separated. Figs 3-4 shows the vortex used in this study.




(a) Closed container (CC) location



(b) Without vortex (WV) location



(c) Connected vortex (CV) location



(d) Separated vortex (SV) location

Fig. 2. Variable location




Fig. 3. Connected vortex (CV)




Fig. 4. Separated vortex (SV)

Refrprop™ software version 10.0.0.9b is used to determine the properties of the refrigerant at enthalpy at each point based on the cooling system performance data by analyzing the saturation pressure, temperature, enthalpy, entropy, and density of the refrigerant [24], [25]. System performance is analysed using pressure and temperature obtained through calculations on R410A refrigerant using Refprop™ software [26]. The effectiveness of an air conditioner is evaluated by determining the refrigeration effect, which is the difference in refrigerant enthalpy between the evaporator's inlet and outlet, and the compression work, which is the enthalpy difference between the compressor's outlet and inlet. The values of RE, CW, and COP are determined based on the obtained enthalpy results [27]. The RE, CW, COP are determined using Eqs(1-3) [28]. Where: h_1 is enthalpy at the compressor inlet, h_2 is Enthalpy at the compressor outlet, and h_4 is enthalpy at the Evaporator inlet.

$$RE = h_1 - h_4 \quad (1)$$

$$CW = h_2 - h_1 \quad (2)$$

$$COP = \frac{RE}{CW} = \frac{h_1 - h_4}{h_2 - h_1} \quad (3)$$

Results and Discussion

This study examines the performance of WAC for utilization as a desalination tool with four variables: CC, WV, CV, and SV. Fig. 5 shows the data collection process. At points 1 to 4, data of P_1 , T_1 , P_2 , T_2 , P_3 , T_3 , P_4 , and T_4 are collected sequentially. The digital scale at point 5 is used to measure the mass of water in the evaporation container to determine the decrease in mass due to evaporation. The seawater in the main container was heated by a condenser controlled by a thermostat to maintain a temperature between 55-60°C. Data was collected every 5 minutes for 8 hours. The system performance is greatly affected by the evaporation rate, which impacts the COP value of the WAC. In addition, this process demonstrates how the integration of vortex generators can improve desalination efficiency.




Fig. 5. WAC as a desalination devices

Fig. 6 shows the pressure-enthalpy (P-h) diagram for R410A refrigerant at various variables, namely CC, WV, CV, and SV. The enthalpy values are obtained from the calculation results using Refprop™ software, with input data in the form of pressure and temperature at each point: P_1 , T_1 , P_2 , T_2 , P_3 , T_3 , P_4 , and T_4 . The average evaporator exit air temperature for each variable is 17.8°C, 18.6°C, 18.7°C, and 18.9°C, respectively. Meanwhile, the condenser exit air temperatures were 55.7°C, 56.3°C, 56.9°C, and 57.1°C, respectively. Based on the enthalpy values obtained, the performance of the WAC system can be calculated, including the RE, CW, and COP values.




Fig. 6. P-h diagram for R410A with a closed container, without vortex, connected vortex, and separated vortex

In a refrigeration system, efficiency is crucial to consider. One concept that plays a role in measuring the efficiency of a refrigeration system is the RE, which is the amount of heat absorbed by the refrigerant in the evaporator for each unit mass of cooling, which occurs in the process from 4 to 1 [29], [30]. By calculating using Eq. 1, the RE of R410A for various CC, WV, CV, and SV variables in the desalination process is shown in Fig. 7. The results show a decrease in RE; a lower refrigeration effect can lower COP [31]. The latent heat of vaporization in the Air Conditioning (AC) system comes from the evaporation of refrigerant [32]. The closed container of R410A has the highest RE value. The high RE value is due to the latent heat of vaporization [33] and high enthalpy compared to the other variable, R410A. As a result, the desalination process using closed-container R410A yields better cooling capacity than the other variable, R410A.




Fig. 7. Refrigeration effect and compression work with closed container, without vortex, connected vortex, and separated vortex.

Meanwhile, the CW of R410A for various variables, the CW value in the figure is calculated using Eq.2. Unlike RE, CW has a constant increase. This is due to the increase in compressor pressure, the refrigerant temperature [34], and enthalpy. An increase in refrigerant pressure can increase compressor work, thus decreasing the COP value [35]. CW of the closed container R410A is lower than that of the other variable R410A. This indicates that the R410A refrigerant in the sealed container has a lower temperature, so the compressor workload is lighter [36].

The COP is calculated using Eq. 3, and Fig. 8 shows that the COP value decreases as the evaporation increases. The use of a vortex increases the evaporation rate and efficiency in the desalination unit, resulting in faster evaporation [37], [38]. CV and SV have different geometry so it can affect the characteristics of airflow. CV has fewer and connected, while SV with more separated numbers produces better evaporation and increased effectiveness [39].




Fig. 8. Evaporation and COP with closed container, without vortex, connected vortex, and separated vortex.

On the other hand, an increase in refrigerant in the refrigeration machine can lead to an increase in temperature in the condenser, which requires greater compression effort [40]. The condenser located inside the main container helps to heat the water and increase evaporation as the temperature rises. The increased evaporation temperature from the condenser is then transferred to the evaporator through a steam funnel designed to direct the incoming air to the evaporator. The CC is secured with plates to prevent evaporation in the condenser from affecting the temperature of the air entering the evaporator. This causes a high refrigeration effect and reduces compression work, resulting in an optimal COP.

4 Conclusion

This study demonstrates that incorporating a vortex generator into a modified WAC significantly impacts seawater evaporation

rates in desalination. The SV configuration produced the highest evaporation rate (5.01 kg) but reduced system efficiency by increasing compressor workload, leading to a lower COP (3.91). Conversely, the CC condition achieved the highest COP (5.08) by minimizing heat loss and stabilizing air temperature entering the evaporator. These findings highlight the trade-off between evaporation enhancement and system efficiency.

Future research should explore alternative vortex configurations, large scale testing, and environmental variations to optimize WAC-based desalination systems.

Acknowledgment

The author would like to express sincere gratitude for the in-kind support provided by the Renewable Energy Research Group at FTII UHAMKA.

References

- [1] P. Martínez, J. Ruiz, C. G. Cutillas, P. J. Martínez, A. S. Kaiser, and M. Lucas, "Experimental study on energy performance of a split air-conditioner by using variable thickness evaporative cooling pads coupled to the condenser," *Appl. Therm. Eng.*, vol. 105, pp. 1041–1050, 2016, doi: 10.1016/j.applthermaleng.2016.01.067.
- [2] M. H. Alhamdo, M. A. Theeb, and J. J. Abdulhameed, "Using evaporative cooling methods for improving performance of an Air-cooled Condenser," *Univers. J. Mech. Eng.*, vol. 3, no. 3, pp. 94–106, 2015, doi: 10.13189/ujme.2015.030304.
- [3] K. Harby, D. R. Gebaly, N. S. Koura, and M. S. Hassan, "Performance improvement of vapor compression cooling systems using evaporative condenser: An overview," *Renew. Sustain. Energy Rev.*, vol. 58, pp. 347–360, 2016, doi: 10.1016/j.rser.2015.12.313.
- [4] N. D. Purnama, T. P. Pramudiantoro, and A. Badarufin, "Kaji eksperimental perbandingan performansi ac split sebelum dan sesudah pemanfaatan panas buang kondenser untuk alat penetas telur," *Pros. Ind. Res. Work. Natl. Semin.*, vol. 15, no. 1, pp. 64–70, 2024, doi: 10.35313/irwns.v15i1.6242.
- [5] N. I. Ibrahim, A. A. Al-Farayedhi, and P. Gandhidasan, "Experimental investigation of a vapor compression system with condenser air pre-cooling by condensate," *Appl. Therm. Eng.*, vol. 110, pp. 1255–1263, 2017, doi: 10.1016/j.applthermaleng.2016.09.042.
- [6] M. W. Akram, R. Mursalin, M. M. Hassan, M. R. Islam, and S. K. Choudhury, "recycling of condensed water from an air conditioning unit," in *International Conference on Computer, Communication, Chemical, Material and Electronic Engineering, IC4ME2, IEEE*, 2018, pp. 1–5. doi: 10.1109/IC4ME2.2018.8465612.
- [7] A. Gross and E. Park, "Water and wastewater treatment worldwide: The industry and the market for equipment and chemicals," *Bus. Econ.*, vol. 53, no. 2, pp. 37–47, 2018, doi: 10.1057/s11369-018-0069-1.
- [8] D. Mugisidi, A. Fajar, and H. Oktarina, "Peningkatan efisiensi dan efektivitas kondensor pada solar still," *J. Teknosains*, vol. 12, no. 1, pp. 19–31, 2022.
- [9] J. J. Messakh, A. Sabar, I. K. Hadihardaja, and A. A. Chalik, "A study on fulfillment of drinking water need of people in semi-arid areas in Indonesia," *J. Mns. dan Lingkung.*, vol. 22, no. 3, pp. 271–280, 2015.
- [10] A. A. Ragetisvara and H. S. Titah, "Studi kemampuan desalinasi air laut menggunakan sistem sea water reverse osmosis (swro) pada kapal pesiar," *J. Tek. ITS*, vol. 10, no. 2, pp. 68–75, 2021, doi: 10.12962/j23373539.v10i2.63933.
- [11] L. A. Yoshi and I. N. Widiasta, "Prosiding seminar nasional teknik kimia 'kejuangan' sistem desalinasi membran reverse osmosis (RO) untuk penyediaan air bersih," in *Prosiding Seminar Nasional Teknik Kimia "Kejuangan"*, 2016, pp. 1–7.

- [12] B. Shen and B. Fricke, "Development of high efficiency window air conditioner using propane under limited charge," *Appl. Therm. Eng.*, vol. 166, p. 114662, 2020, doi: 10.1016/j.applthermaleng.2019.114662.
- [13] A. E. Kabeel, M. Abdelgaied, and Z. M. Omara, "Experimentally evaluation of split air conditioner integrated with humidification-dehumidification desalination unit for better thermal comfort, produce freshwater, and energy saving," *J. Therm. Anal. Calorim.*, vol. 147, no. 6, pp. 4197–4207, 2022, doi: 10.1007/s10973-021-10810-6.
- [14] M. Abdelgaied, A. E. Kabeel, and Y. Zakaria, "Performance improvement of desiccant air conditioner coupled with humidification-dehumidification desalination unit using solar reheating of regeneration air," *Energy Convers. Manag.*, vol. 198, p. 111808, 2019, doi: 10.1016/j.enconman.2019.111808.
- [15] A. E. Kabeel, M. Abdelgaied, and Y. Zakaria, "Performance evaluation of a solar energy assisted hybrid desiccant air conditioner integrated with HDH desalination system," *Energy Convers. Manag.*, vol. 150, pp. 382–391, 2017, doi: 10.1016/j.enconman.2017.08.032.
- [16] P. Dalai, P. Nanda, C. Mund, D. Mishra, and A. Gupta, "An experimental study on water harvesting from a modified window air-conditioner," *Energy Procedia*, vol. 109, pp. 253–260, 2017, doi: 10.1016/j.egypro.2017.03.058.
- [17] D. Mugisidi and O. Heriyani, "Improving the performance of a forced-flow desalination unit using a vortex generator," *CFD Lett.*, vol. 16, no. 10, pp. 81–93, 2024, doi: 10.37934/cfdl.16.10.8193.
- [18] A. N. Shmroukh, A. A. Serageldin, A. Abdal-hay, A. Elreedy, and A. Radwan, "Application of new series connection scheme of vortex tubes in seawater desalination unit using new vortex generators," *SN Appl. Sci.*, vol. 3, pp. 1–13, 2021, doi: 10.1007/s42452-021-04205-3.
- [19] O. Heriyani, M. Djaeni, Syaiful, and A. K. Putri, "Perforated concave rectangular winglet pair vortex generators enhance the heat transfer of air flowing through heated tubes inside a channel," *Results Eng.*, vol. 16, pp. 1–15, 2022, doi: 10.1016/j.rineng.2022.100705.
- [20] J. Williams, "Desalination in the 21st Century: A Critical Review of Trends and Debates," *Water Altern.*, vol. 15, no. 2, pp. 193–217, 2022.
- [21] Widodo, F. Rachmanu, and A. I. Tauvana, "analysis of savings on electricity consumption in room air conditioning by using r1270 (propylene) refrigerant instead of R32 capacity of 13,000 Btuh," *J. Phys. Conf. Ser.*, vol. 1477, no. 5, pp. 1–6, 2020, doi: 10.1088/1742-6596/1477/5/052035.
- [22] I. G. A. Negara et al., "Real-time thermodynamic monitoring of split inverter ACs: a microcontroller-driven investigation of performance," *J. Polimesin*, vol. 22, no. 2, pp. 199–205, 2024.
- [23] R. Wirangga, D. Mugisidi, A. T. Sayuti, and O. Heriyani, "The impact of wind speed on the rate of water evaporation in a desalination chamber," *J. Adv. Res. Fluid Mech. Therm. Sci.*, vol. 106, no. 1, pp. 39–50, 2023, doi: 10.37934/arfm.106.1.3950.
- [24] E. W. Lemmon, I. H. Bell, M. L. Huber, and M. O. McLinden, "NIST Standard reference database 23: reference fluid thermodynamic and transport properties-REFPROP, version 10.0, National Institute of Standards and Technology."
- [25] M. L. Huber, E. W. Lemmon, I. H. Bell, and M. O. McLinden, "The NIST REFPROP database for highly accurate properties of industrially important fluids," *Ind. Eng. Chem. Res.*, vol. 61, no. 42, pp. 15449–15472, 2022, doi: 10.1021/acs.iecr.2c01427.
- [26] Widodo, B. Fajar, T. Suryo, and Winoto, "Simulation of mixing synthetic with hydrocarbons refrigerant to reduce the value of global warming potential with reprop software," *J. Phys. Conf. Ser.*, vol. 1764, no. 1, pp. 1–6, 2021, doi: 10.1088/1742-6596/1764/1/012158.
- [27] M. E. Pujianto and A. Nugroho, "Performance air conditioner on retrofitted refrigerant hydrocarbon," *J. Polimesin*, vol. 22, no. 1, pp. 15–18, 2024, doi: 10.1063/1.5049962.
- [28] K. Sumeru, M. Arman, I. Wellid, L. M. Simbolon, A. Setyawan, and M. F. bin Sukri, "Investigation of automotive air conditioning using eco-friendly R600a as an alternative refrigerant to R134a," *J. Polimesin*, vol. 22, no. 1, pp. 35–39, 2024, doi: 10.30811/jpl.v22i1.4463.
- [29] R. K. Sahu, Vinay, and A. Das, "Refrigerating effect produced by engine exhaust heat," *Adv. Fluid Therm. Eng.*, pp. 489–498, 2019, doi: 10.1007/978-981-13-6416-7_45.
- [30] I. N. Ardita and I. P. S. Negara, "Pengaruh heat recovery pada sistem refrigerasi pengkondisian udara terhadap performansi sistem," *J. Log.*, vol. 16, no. 3, pp. 199–203, 2016.
- [31] W. Widodo, B. F. T. Kiono, S. H. Winoto, and M. S. K. T. S. Utomo, "A simulation of R32 refrigerant mixing with R1270 to reduce GWP R410A on wall mounted air conditioning," *IOP Publ.*, vol. 1098, no. 6, pp. 1–7, 2021, doi: 10.1088/1757-899x/1098/6/062111.
- [32] G. Fekadu and S. Subudhi, "Renewable energy for liquid desiccants air conditioning system: A review," *Renew. Sustain. Energy Rev.*, vol. 93, pp. 364–379, 2018, doi: 10.1016/j.rser.2018.05.016.
- [33] Y. Sun, J. Wang, and Y. Hu, "Effect of refrigerant/oil solubility on thermodynamic performance of the evaporator working with R600a and DME," *J. Chem. Thermodyn.*, vol. 154, pp. 1–8, 2021, doi: 10.1016/j.jct.2020.106331.
- [34] S. M. Moosania and X. Zheng, "Performance improvement of a high pressure ratio centrifugal compressor by integrated cooling," *Proc. Inst. Mech. Eng. Part G J. Aerosp. Eng.*, vol. 230, no. 12, pp. 2233–2240, 2015, doi: 10.1177/0954410015622964.
- [35] Widodo, B. F. T. Kiono, S. H. Winoto, and T. S. Utomo, "Performance analysis of using hydrocarbon mixed refrigerant r32-r290 as an alternative to R410A in reducing the GWP value of household split air conditioners," *J. Adv. Res. Fluid Mech. Therm. Sci.*, vol. 107, no. 2, pp. 103–116, 2023, doi: 10.37934/arfm.107.2.103116.
- [36] A. Setyawan, "Enhancing air conditioner efficiency through evaporative cooling of the compressor: field test results," *Int. J. Heat Technol.*, vol. 42, no. 3, pp. 1073–1080, 2024, doi: 10.18280/ijht.420334.
- [37] O. Heriyani, M. Djaeni, and Syaiful, "Thermal-hydraulic performance analysis by means of rectangular winglet vortex generators in a channel: An Experimental Study," *Eur. J. Eng. Technol. Res.*, vol. 6, no. 3, pp. 150–153, 2021, doi: 10.24018/ejers.2021.6.3.2424.
- [38] M. A. Saad, A. E. Tourab, M. H. Salem, and A. Ismail, "Multifaceted analytical and computational fluid dynamics investigations of vortex tube technology for the optimization of seawater desalination efficiency," *Results Eng.*, vol. 25, pp. 1–12, 2025, doi: 10.1016/j.rineng.2025.104004.
- [39] D. Mugisidi, O. Heriyani, P. H. Gunawan, and D. Apriani, "Performance improvement of a forced draught cooling tower using a vortex generator," *CFD Lett.*, vol. 13, no. 1, pp. 45–57, 2021, doi: 10.37934/cfdl.13.1.4557.
- [40] A. I. Rifa'i and Novarini, "pengaruh tekanan refrigeran r-134a terhadap nilai coefficient of performance (COP)," *J. Inov.*, vol. 1, no. 1, pp. 1–5, 2018, doi: 10.37338/ji.v3i2.136.